

Addendum No.1, RFP 15-40-Rebid



CITY OF SOMERVILLE, MASSACHUSETTS
Department of Purchasing
JOSEPH A. CURTATONE
MAYOR

To: Prospective bidders RFP 15-40-Rebid, Engine 3 Modular Construction

From: Alex Nosnik, Assistant Director, Purchasing

Date: 12/16/2014

Re: Questions & Answers

Addendum No. 1 to RFP 15-40-Rebid

The City is issuing this addendum to FP 15-40-Rebid Engine 3 Modular Construction to provide additional information:

****PLEASE BE SURE TO ACKNOWLEDGE THIS ADDENDUM BELOW****

1. Change in Due Date:

- **Proposals are now due 12/18/14 at 11AM EST.**

2. Questions and Answers:

Q. Please provide the name and contact information for the firm who holds the existing fire alarm maintenance contract whom we are required to hire to perform final connections, programming and testing of the fire alarm system.

A. The Contractor's name is Simplex Grinnell, L. 63 Nahatan St., Norwood, MA 02062 781-828-5310. The current contract will expire on 12/31/14 and has been renewed through 12/31/15.

Q. Please provide the location of the existing fire alarm control panel that we are required to tie the new modular fire alarm devices into so that we may determine the distance between this panel and the new modular fire alarm terminal cabinet.

A. The existing alarm panel is located in the small office in the garage of the existing public safety building.

Addendum No.1, RFP 15-40-Rebid

Q. Please advise if the fire alarm system has speakers for voice evacuation or horns with a standard 3-pulse temporal signal pattern for notification appliances.

A. Fire alarm system is a complete addressable fire detection, alarm and control system with horn/strobe signaling devices non voice evac system. Match existing as indicated on drawings E0.1, paragraphs 2.11 and 3.11. and E4.1.

Please acknowledge receipt of this Addendum by signing below and including this form in your proposal package. Failure to do so may subject the proposer to disqualification.

X

Name of Authorized Signatory

Title of Authorized Signatory